

ORDINANCE NO. 37

AN ORDINANCE AMENDING ORDINANCE NO. 4,
"AN ORDINANCE ESTABLISHING RATES, RULES
AND REGULATIONS FOR WATER SERVICE BY
THE SUNNYSLOPE COUNTY WATER DISTRICT,"
AS AMENDED

BE IT ORDAINED by the Board of Directors of the Sunnyslope
County Water District, San Benito County, California, as follows:

Section 1. Section 154 of Article 8 of Ordinance No. 4,
entitled "An Ordinance Establishing Rates, Rules and Regulations for
Water Service by the Sunnyslope County Water District," passed and
adopted September 8, 1955, as amended, shall be, and it is hereby,
repealed.

Section 2. Sections 149, 150 and 151 of Article 8 of Ordinance
No. 4, entitled "An Ordinance Establishing Rates, Rules and Regulations
for Water Service by the Sunnyslope County Water District," passed and
adopted September 8, 1955, as amended, shall be, and it is hereby,
amended to read, as follows:

"149. Cross-Connections-Backflow Devices. The
customer must comply with the State and Federal Laws governing
the separation of dual water systems or installations of
backflow protective devices to protect the public water supply
from the danger of cross-connections. Backflow protective
devices must be installed as near the service as possible and
shall be open to test and inspection by the Water Department.
Plans for installation of backflow protective devices must be
approved by the Water Department prior to installation.

In special circumstances, when the customer is engaged
in the handling of especially dangerous or corrosive liquids or
industrial or process waters, the District may require the
customer to eliminate certain plumbing or piping connections as
an additional precaution and as a protection of the backflow
preventive devices.

As a protection to the customer's plumbing system, a
suitable pressure relief valve must be installed and maintained
by him, at his expense, when check valves or other protective
devices are used. The relief valve shall be installed between
the check valves and the water heater.

Whenever backflow protection has been found necessary on
a water supply line entering a customer's premises, then any and
all water supply lines from the District's mains entering such
premises, buildings, or structures shall be protected by an
approved backflow device, regardless of the use of the
additional water supply line.

150. Id.--Inspection. The double check valve or other approved backflow protection devices may be inspected and tested periodically for water tightness by the District. The devices shall be serviced, overhauled or replaced whenever they are found defective and all costs of repair and maintenance shall be borne by the customer.

151. Id.--Discontinuance of Service. The service of water to any premises may be immediately discontinued by the District if any defect is found in the check valve installation or other protective devices, or if it is found that dangerous unprotected cross-connections exist. Service will not be restored until such defects are corrected."

Section 3. This ordinance shall be posted in three public places within the District.

Section 4. This Ordinance shall take effect immediately after its adoption.

Section 5. All ordinances or parts of ordinances inconsistent herewith are hereby repealed.

ATTEST:


Secretary

(SEAL)

* * * * *

I hereby certify that the foregoing Ordinance was duly and regularly adopted and passed by the Board of Directors of the Sunnyslope County Water District at a meeting thereof held on the 9th day of July, 1987, by the following vote:

AYES, and in favor hereof, Directors: Blaettler, Churchill,
~~Hailstone~~, Renz, Williams

NOES, Directors: None

ABSENT, Directors: ~~None~~ Hailstone


Secretary

Sunnyslope County Water District

CERTIFICATE OF POSTING

ORDINANCE NO. 37

SUNNYSLOPE COUNTY WATER DISTRICT

J. W. JACKSON, under penalty of perjury, certifies as follows:

That he is a citizen of the United States and over the age of eighteen years;

That he is, and during all times herein mentioned was, the duly acting and qualified Secretary of the Sunnyslope County Water District, and that on the 13 day of July, 1987, he caused to be posted copies of Ordinance No. 37, An Ordinance Amending Ordinance No. 4, An Ordinance Establishing Rates, Rules and Regulations for Water Service by the Sunnyslope County Water District, at three public places within said District, to wit:

1. District Office
3416 Arline Highway
Hollister, California
2. Ridgemark Club House
Ridgemark Drive
Hollister, California
3. Sunnyslope Elementary School
1475 Memorial Drive
Hollister, California


J. W. JACKSON, Secretary